

Minimum device firmware requirements of GridVis 2.5.0

Stand 28.02.2012

device	required firmware	comment
UMG604	1.293 or later	devices prior to firmware version 1.048 have to get modernised hardware (renew Atmel)
UMG605	1.293 or later	
UMG104	1.268 or later	
UMG511	1.293 or later	
UMG508	1.293 oder neuer	
UMG103	no limitations	
UMG96	no limitations	
UMG96S	1.20 or later	
UMG503	3.102 or later	will not be checked by GridVis 2.X.X devices prior to HW-Version 0.40 (firmware version 2.004) have to be replaced
UMG505	no limitations	series 2 and series 3
UMG507	0.993	will not be checked by GridVis 2.X.X
UMG 510	1.037	
UMG96RM	0.50 or later	will not be checked by GridVis 2.X.X
Prophi	no limitations	